

## Classification Report

Number	19-002959-PR02 (NW-A01-02-en-01)
Owner	ALUMIL S.A. Industrial Area 61100 Kilkis Greece
Product	Tilt and turn casement door
Designation	Shipping name: S91
Details	Manufacturer CFT-CARBON FIBER TECHNOLOGIES, PRIVATE COMPANY - Kilkis; Material Aluminium system with thermal break; Type of opening Tilt and turn; Opening direction DIN right, inward opening; Overall dimensions (W x H) 1200 mm x 2500 mm
Special features	Material compatibility must be taken into account. Material durability must be taken into account.

### Result

Air permeability according to EN 12207:2016-12



**Class: 4**

Resistance to wind load according to EN 12210:2016-03



**Class: C5/B5**

Watertightness according to EN 12208:1999-11



**Class: E1650**

### Basis \*)

EN 14351-1:2006+A2:2016-09  
\*) and corresponding national versions  
(e.g. DIN EN)

Test report: 19-002959-PR02 PB-A01-02-en-01

### Representation



### Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

### Validity

There is no time limit.  
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

### Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

### Identity-Check



[www.ift-rosenheim.de/ift-geprueft](http://www.ift-rosenheim.de/ift-geprueft)  
ID: 784-DF91C

ift Rosenheim  
10.08.2019



Thomas Stefan, Dipl.-Ing. (FH)  
Head of Testing Department  
Building Component Testing



Dimitrios Moustakidis, MSc, Dipl.-Ing.  
Operating Testing Officer  
Building Component Testing